# Annual Drinking Water Quality Report

MANITO

IL1250300

Annual Water Quality Report for the period of January 1 to December 31, 2017

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by MANITO is Ground Water

For more information regarding this report contact:

Steve Sondag Phone (309) 948-7080

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

## Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

 Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

 Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

brinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EpA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe prinking water Hotline (800-426-4791).

serious health problems, especially for pregnant If present, elevated levels of lead can cause plumbing components. When your water has been We cannot control the variety of materials used in associated with service lines and home plumbing is primarily from materials and components drinking or cooking. If you are concerned about sitting for several hours, you can minimize the women and young children. Lead in drinking water Drinking Water Hotline or at minimize exposure is available from the Safe water, testing methods, and steps you can take to water tested. Information on lead in drinking lead in your water, you may wish to have your for 30 seconds to 2 minutes before using water for potential for lead exposure by flushing your tap

WELL 5 (00744)

Repor

Report Status Location

IN WTB 3

350 FT SE OF WELL 4

GW

GW

04/18/2018 - IL1250300\_2017\_2018-04-18\_10-08-34.PDF

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at  $\frac{Q_0}{1080}$ . To view a summary version of the completed Source Water Assessments, including: Importance of Source Water Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl.

Source of Water: WANITOTO determine Manito's susceptibility to groundwater contamination, a Well Site Survey, published in 1990, was reviewed. During the survey of Manito's source water protection area, Illinois EPA staff recorded two potential sources, routes, or possible problem sites within the 400 foot minimum setback zone and one within the 1000 foot maximum setback zone of well #4. In addition, inactive well #3 is located with the maximum setback zone of well #4. No potential sources, routes, or possible problem sites were found within the minimum or maximum setback zones of well #5 or the recharge area for either well. Fourteen additional sites within 3,000 feet of the wells were found by IRWA. The Illinois EPA considers the source water of this facility to be susceptible to contamination. This determination is based on a number of criteria including: monitoring conducted at the wells, monitoring conducted at the entry point to the distribution system, and the available hydrogeologic data on the wells.

#### Lead and Copper

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin

of

safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

wood preservatives; Corrosion of household plumbing systems.	z	ppm	0	0.36	1.3	1.3	08/31/2016	Copper
1								
Likely Source of Contamination	Violation	Units	# Sites Over Units	90th Percentile	Action Level (AL)	MCLG	Date Sampled	Lead and Copper Date Sa

## Water Quality Test Results

Definitions:

Level 1 Assessment:

Avg:

Level 2 Assessment:

Maximum Contaminant Level or MCL:

Maximum Contaminant Level Goal or MCLG:

Maximum residual disinfectant level or

goal or MRDLG: Maximum residual disinfectant level

na:

: mdd Treatment Technique or TT:

: ddd mrem:

The following tables contain scientific terms and measures, some of which may require explanation.

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

using the best available treatment technology. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

millirems per year (a measure of radiation absorbed by the body)

micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

A required process intended to reduce the level of a contaminant in drinking water.

### Regulated Contaminants

Erosion of natural deposits.	N	pci/L	.σ.	0	0.565 - 1.76	1.76	04/15/2015	Combined Radium 226/228
Likely Source of Contamination	Violation	Units	MCL	MCLG	Range of Levels Detected	Highest Level Detected	Collection Date	Radioactive
This contaminant is not currently regulated by the USEPA. However, the state regulates. Naturally occurring; discharge from metal	N	ppm	ιπ	51	0.0076 - 0.021	0.021	04/15/2015	Zinc
Erosion from naturally occuring deposits. Used in water softener regeneration.	N	ppm			5.3 - 6.2	6.2	04/15/2015	Sodium
This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.	N	ppb	150	150	110 - 110	110	04/15/2015	Manganese
This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.	N	ppm	1.0		0.7 - 0.98	0.98	04/15/2015	Iron
Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	N	māđ	ю	2	0.13 - 0.16	0.16	04/15/2015	Barium
Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	×	ppb	10	0	4 - 4.3	4.3	04/15/2015	Arsenic
Likely Source of Contamination	Violation	Units	MCL	MCLG	Range of Levels Detected	Highest Level Detected	Collection Date	Inorganic Contaminants
By-product of drinking water disinfection	N	ppb	80	No goal for the total	19.24 - 19.24	19	2017	Total Trihalomethanes (TTHM)
By-product of drinking water disinfection.	z	qđđ	60	No goal for the total	3.6 - 3.6	4	2017	Haloacetic Acids (HAA5)
Water additive used to control microbes.	z	ppm	MRDL = 4	MRDLG = 4	0.6 - 1	0.9	12/31/2017	Chlorine
Likely Source of Contamination	Violation	Units	WCL	MCLG	Range of Levels Detected	Highest Level Range of Levels Detected Detected	Collection Date	Disinfectants and Disinfection By- Products